

Tata Memorial Hospital
Engineering Department

Minutes of Pre-Bid Meeting

**Sub: Consultancy services for installation of ETP/STP /Combination of
ETP & STP at Tata Memorial Hospital , Parel.**

Ref: NIT No. TMC/ENG/PRJ/STP/2014/04 dated 04/08/2014

Pre-bid meeting for the above subject work was held on 21/08/2014 at 11.00 hrs in Conference Room, Digital Library, Ground Floor, TMH.

The consultants present in the meeting raised certain queries. The clarifications are as under:

S.NO	Query	Clarification
1	The vendors inquired about total water consumption	Based on the report available with TMH 1. Annexe Bldg.- 8000m ³ /month 2. Main Bldg – 11500m ³ /month 3. GJB – 8500m ³ /month 4. HBB- 4000m ³ /month Considering 30 days a month the daily consumption of water will be 1. Annexe Bldg.- 270m ³ /per day 2. Main Bldg – 385m ³ /per day 3. GJB – 285m ³ /per day 4. HBB- 135m ³ /per day
2	Chemical Analysis Report of the sewage.	Photo copies enclosed (3 Nos)
3	General Layouts of the buildings	Photo copies enclosed (1 No)
4	Whether service tax will be paid extra	Applicable Service Tax will be payable
5	Requested for the extension of time for submission of tender	Date of submission is extended upto 15.00 hrs on 03/09/2014. Date of opening of the tender 15.30 hrs on 03/09/2014

Note : 1. All bidders are again reminded of the fact that conditional tender shall stand rejected without any discussion on the subject.

2. All the clarification given shall be part of the tender.

3. All bidders shall stamp and sign all the tender document including minutes of Pre-bid meeting , Photo copies of general layout and chemical analysis report.

**Sd/-
M.K.Nate
Engineer (Civil)**