



Doctors' Analytical Laboratories Pvt. Ltd.

The Science of Testing. The Art of Serving

CERTIFICATE OF ANALYSIS

QSF NO.: 5.10.01

Customer Name & Address: Masumo Inc
Burjor Bldg, Ground Floor, Wadia Street, Tardeo, Mumbai- 400 034

Report No.: 12718
Report Date (dd/mm/yyyy): 30/09/2013
Customer Ref. No.:
Any other Information:


Sample Name: Water sample
Sample Category: Water
Sample Received Date: 23/09/2013
Quantity: 800 MilliLitre
Laboratory Code: 113090113 / Sample 2
Sample Description: Turbid liquid with suspended particles.

Other Details: Tata Memorial Hospital-Collection Point No.6, Last Chamber, Golden Jubilee Block
Analysis completed on: 30/09/2013
Packing Details: Plastic container # Sealed
Batch no.: Sample 2
Sample Not Drawn by DALPL

Sr.No.	Name Of Test	Result	Method Of Analysis	Equipments
Chemical Test				
1	Biochemical Oxygen Demand	8 mg/L	IS: 3025(Part-44)1993 RA 2003	-
2	Chemical Oxygen Demand	19 mg/L	IS: 3025 (Part-58) 2006	-
3	Total Suspended Solids	267 mg/L	IS: 3025(Part-17) 1984	-
4	Total Dissolved Solids	500 mg/L	IS:3025 (Part 16) 1984 RA 2002	-
5	pH	7.46	IS: 3025 (P-11) -1983 RA 2002	-
6	Oil & Grease	55 mg/L	IS : 3025 (Part-39) 1986 Reaff 2003	-

Note : Sample Not Drawn by DALPL.




(Mr. Anand Sathe)
Authorized Signatory
FOR DAL PVT.LTD.

End Of Test Report

