



Doctors' Analytical Laboratories Pvt. Ltd.

The Science of Testing. The Art of Serving

CERTIFICATE OF ANALYSIS

QSF NO.: 5.10.01

Customer Name & Address	Masumo Inc Burjor Bldg. Ground Floor, Wadia Street, Tardeo, Mumbai- 400 034	Report No.	12719
		Report Date (dd/mm/yyyy)	30/09/2013
		Customer Ref. No.	
		Any other Information	

Sample Name	Water sample	Other Details:	Tata Memorial Hospital - Collection Point No.4, Last Chamber, Annex Building
Sample Category	Water	Analysis completed on	30/09/2013
Sample Received Date	23/09/2013	Packing Details	Plastic container # Sealed
Quantity	800 MilliLitre	Batch no.	Sample 3
Laboratory Code	113090113 / Sample 3	Sample Not Drawn by DALPL	
Sample Description	Turbid liquid with suspended particles.		

Sr.No.	Name Of Test	Result	Method Of Analysis	Equipments
Chemical Test				
1	Biochemical Oxygen Demand	18 mg/L	IS: 3025(Part-44)1993 RA 2003	-
2	Chemical Oxygen Demand	49 mg/L	IS: 3025 (Part-58) 2006	-
3	Total Suspended Solids	215 mg/L	IS: 3025(Part-17) 1984	-
4	Total Dissolved Solids	448 mg/L	IS:3025 (Part 16) 1984 RA 2002	-
5	pH	7.37	IS: 3025 (P-11) -1983 RA 2002	-
6	Oil & Grease	134 mg/L	IS : 3025 (Part-39) 1986 Reaff 2003	-

Note : Sample Not Drawn by DALPL.



(Mr. Anand Sathe)
Authorized Signatory
FOR DAL PVT.LTD.

End Of Test Report

