



Doctors' Analytical Laboratories Pvt. Ltd.
The Science of Testing. The Art of Serving

CERTIFICATE OF ANALYSIS

QSF NO.: 5.10.01

Customer Masumo Inc
Address & Pin No. Burjor Bldg, Ground Floor, Wadia Street, Tardeo, Mumbai- 400 034

Report No. 12717
Report Date (dd/mm/yyyy) 30/09/2013
Customer Ref. No.
Any other Information

Sample Name Water sample
Sample Category Water

Other Details: Tata Memorial Hospital - Collection Point Number 3, Last Chamber, Main Building

Sample Received Date 23/09/2013
Quantity 800 MilliLitre

Analysis completed on 30/09/2013
Packing Details Plastic container # Sealed

Laboratory Code 113090113 / Sample 1
Sample Description Turbid liquid with suspended particles.

Batch no. Sample 1
Sample Not Drawn by DALPL

Sl. No.	Name Of Test	Result	Method Of Analysis	Equipments
Chemical Test				
1	Biochemical Oxygen Demand	48 mg/L	IS: 3025(Part-44)1993 RA 2003	-
2	Chemical Oxygen Demand	136 mg/L	IS: 3025 (Part-58) 2006	-
3	Total Suspended Solids	698 mg/L	IS: 3025(Part-17) 1984	-
4	Total Dissolved Solids	400 mg/L	IS:3025 (Part 16) 1984 RA 2002	-
5	pH	6.84	IS: 3025 (P-11) -1983 RA 2002	-
6	Oil & Grease	439 mg/L	IS: 3025 (Part-39) 1986 Reaff 2003	-

Note : Sample Not Drawn by DALPL.



(Mr. Anand Sathe)
Authorized Signatory
FOR DAL PVT.LTD.

End Of Test Report

