



Doctors' Analytical Laboratories Pvt. Ltd.
The Science of Testing. The Art of Serving

CERTIFICATE OF ANALYSIS

QSF NO.: 5.10.01

Customer Masumo Inc
 Name & Address Burjor Bldg, Ground Floor, Wadia Street, Tardeo, Mumbai- 400 034

Report No. 12718
 Report Date (dd/mm/yyyy) 30/09/2013
 Customer Ref. No.
 Any other Information

Sample Name Water sample
 Sample Category Water

Other Details: Tata Memorial Hospital-Collection Point No.6, Last Chamber, Golden Jubilee Block

Sample Received Date 23/09/2013
 Quantity 800 MilliLitre
 Laboratory Code 113090113 / Sample 2
 Sample Description Turbid liquid with suspended particles.

Analysis completed on 30/09/2013
 Packing Details Plastic container # Sealed
 Batch no. Sample 2
 Sample Not Drawn by DALPL.

Sr.No.	Name Of Test	Result	Method Of Analysis	Equipments
Chemical Test				
1	Biochemical Oxygen Demand	8 mg/L	IS: 3025(Part-44)1993 RA 2003	
2	Chemical Oxygen Demand	19 mg/L	IS: 3025 (Part-58) 2006	
3	Total Suspended Solids	267 mg/L	IS: 3025(Part-17) 1984	
4	Total Dissolved Solids	500 mg/L	IS:3025 (Part 16) 1984 RA 2002	
5	pH	7.46	IS: 3025 (P-11) -1983 RA 2002	
6	Oil & Grease	55 mg/L	IS : 3025 (Part-39) 1986 Reaff 2003	

Note : Sample Not Drawn by DALPL.



(Signature)
 (Mr. Anand Sathe)
 Authorized Signatory
 FOR DAL PVT.LTD.

End Of Test Report

